

Type test Certificate of Complete Type Test

Hongshang Heat Shrinkable Materials Co., Ltd.

Shenzhen, China

has successfully passed the type test sequence on a

Three-core heat shrinkable indoor termination

Type: HKIT-15/3x185 A-C 3x185 mm² 8,7/15 (17,5) kV

The test requirements are stated in

IEC 60502-4

The test results are recorded in Certificate No.

TDT 1037-10

This Certificate is issued on 25 August 2010

KEMA Nederland B.V.



P.G.A. Bus
KEMA T&D Testing Services
Managing Director



Type test Certificate of Complete Type Test

Hongshang Heat Shrinkable Materials Co., Ltd.

Shenzhen, China

has successfully passed the type test sequence on a

Three-core heat shrinkable outdoor termination

Type: HKOT-15/3x185 A-C 3x185 mm² 8,7/15 (17,5) kV

The test requirements are stated in

IEC 60502-4

The test results are recorded in Certificate No.

TDT 1038-10

This Certificate is issued on 21 September 2010

KEMA Nederland B.V.



P.G.A. Bus
KEMA T&D Testing Services
Managing Director



Copyright © KEMA Nederland B.V.

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the apparatus will prevail. This document does not imply that KEMA has certified or approved any apparatus other than the specimen tested.